

Dear Mr. Yasar:

Per our conversations and the information you provided to the Walton County building department concerning Gray Water recycling systems, our procedure is to allow those usages as specified in the Florida Building Code. Under the FBC 2004 Plumbing Code appendix "C" allows for gray water recycling systems which discharge only from bathtubs, showers, lavatories, clothes washers and laundry sinks. Recycled gray water shall be utilized only for flushing water closets, and urinals that are located in the same building as the gray water recycling system. The exception if Gray water systems shall be permitted to be used for irrigation when specific approval is given by the authority having jurisdiction. Such systems shall be designed as required by Section 105 of the Florida Plumbing Code.

Sincerely,  
Douglas A. Tillery  
Plans Examiner for Walton County, Florida

---

**From:** Brac Systems [mailto:info@bracsystems.com]  
**Sent:** Monday, June 26, 2006 8:38 AM  
**To:** Doug Tillery  
**Subject:** brac systems

hello doug,  
i was wondering when you are sending me the approval letter of my application for the grey water recycling tank in your county.

best regards  
dennis yasar

---