

Mr. Dennis Yasar
Brac Systems Inc
3571 Ashby Ville St. Laurent
Monterial/Quebec, H4R2K3, Canada

Reference is made to your E-Mail received May 04th 2006 in regards to the Brac Gray Water System.

Upon Reviewing the Bra Gray Water System, with the information Provided in your E-Mail, Dated May 4th 2006
The Florida Building Code Plumbing 2004, Ch 6, Sec. 602.4 Reclaimed Water.

Shall be permitted to be used for flushing water closets and urinals and other fixtures, which do not require potable water, in accordance with Florida Department of Environmental Protection (DEP) Chapter 62-610, F.A.C. Reuse of reclaimed water activities, shall comply with the requirements of DEP Chapter 62-610, F.A.C.

Should you have questions, feel free to contact me at 561-805-6692

Sincerely

Paul E Schmitz
Chief plumbing Inspector
pschmitz@wpb.org