

From: Carol Hurst [mailto:crh@alachuacounty.us]  
Sent: Tuesday, March 27, 2007 3:22 PM  
To: Rhett Cork  
Subject: Re: BRAC grey water system

Rhett,

I have reviewed Appendix C of the Florida Building Code 2004 ed. Plumbing, Gray Water Recycling Systems. The BRAC SYSTEMS would be accepted in Alachua County as long as the complete system is in compliance with the conditions of Appendix C amending Section 301.3 of the Plumbing Code.

Carol Hurst  
Alachua County Building Official  
Alachua County Codes Enforcement  
10 SW 2nd Ave.  
Gainesville, FL 32601  
(352) 338-3284