



## SARASOTA COUNTY

"Dedicated to Quality Service"

November 13, 2007

Eco-Smart, Inc.  
Mr. Mike Evans  
4411 Bee Ridge Rd. #344  
Sarasota, Fl. 34233

Subject: Product Approval

Dear Mr. Evans:

Section 104.11, 2004 Florida Building Code authorizes the Building Official to approve alternate methods or materials not specifically prescribed by the code.

After careful review, we find the use of the BRAC Greywater Recycling System is equivalent to that prescribed in the 2004 Florida Building Code-Plumbing in quality, effectiveness, durability and safety.

Accordingly its use is approved in the unincorporated area of Sarasota County subject to the following:

- Product compliance, installation instructions and use is to be shown on each plan.
- System is to be installed per manufacturer specifications and the requirements found in Appendix C "Gray Water Recycling Systems".
- The building water supply system (central water or well) must be protected with a RPZ backflow device.
- If the use for greywater includes external applications, please contact the Sarasota County Health Department for additional permitting.

Should future code editions render this product less equivalent; this product approval will become null and void.

A copy of this approval will be required with each permit application.

If you have any questions, please contact me.

Sincerely,

Gregory Yantorno, C.B.O.  
Deputy Building Official

Cc: Paul Radauskas, C.B.O., Building Official  
Cc: Dennis Myers, C.B.O., Deputy Building Official