



Eco-Smart, Inc.

TOLL FREE: (888)329-2705 FAX: (941)377-9460 info@eco-smart.com

Palm Beach State College
Drafting and Design Classroom

Light Meter and Heat Meter Field Test Results

Room Size: 1116 Sq. Ft.

Number of units: 4

Size of Units: 21"

Diffuser Type: 2x2 Transitional Troffer w/ Prismatic Pyramidal Lens

Foot Candles: 48 fc at desk level

Temperature: 77 Degrees F at desk level

Time of Readings: 12:00 p.m. 3/25/2011



1116 sq. ft. room is lit by four-21" units with pyramidal prismatic lens.